



A P P R O V A L S ®

Certificate of Conformity

Certificate No.: SAA-181917-EA

Certificate Holder: Citisolar QLD Pty Ltd As Trustee For
PGK Distributors Unit Trust t/as
PGK Distribution
8 Mohr Street
Tullamarine VIC 3043
Australia

Class Description: DC Isolator
Product Description: PV Switch-disconnector

Brand Name:



Model No.:

SE030A

Markings:

1000Vdc (Ie=13, 32A),
800Vdc (Ie=32, 45A),
600Vdc (Ie=32, 50A)
Ta: -40°C to +85°C, DC-PV2, IP66NW

Standard:

AS 60947.3:2018
AS/NZS IEC 60947.1:2015

Conditions:

Nil

Approval Mark:

SAA-181917-EA or RCM

Date First Registered:

16 July 2018

Date of Expiry:

16 July 2023

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 16-07-18 181917/1

www.jas-anz.org/register



A P P R O V A L S ®

Certificate of Conformity

* Addendum *

Certificate No.: SAA-181917-EA

Date of Issue: 16 July 2018

Class Description: DC Isolator

Product Description: PV Switch-disconnector

Additional Models

SE030B

SE030E

SE042E

Description

Similar to SE030A except with PV-connector common MC4.

Similar to SE030A except with PV-connector genuine MC4.

Similar to SE30E except for model number.

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 16-07-18 181917/2



A P P R O V A L S ®

Certificate of Conformity

* Addendum *

Certificate No.: SAA-181917-EA

Date of Issue: 23 July 2018

Class Description: DC Isolator

Product Description: PV Switch-disconnector

Additional Models

SE042B

Description

Similar to SE30E except for model number.

A handwritten signature in black ink, appearing to be 'SAA', located above a horizontal line.

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 23-07-18 181917/3



A P P R O V A L S ®

Certificate of Conformity

* Addendum *

Certificate No.: SAA-181917-EA

Date of Issue: 5 March 2019

Class Description: DC Isolator

Product Description: PV Switch-disconnector

General Modification:

For models SE030A, SE030B, SE030E, SE042E and SE042B:

Rating reduced from:-

1000Vdc (Ie=13, 32A), 800Vdc (Ie=32, 45A), 600Vdc (Ie=32, 50A); to

1000Vdc (Ie=9, 32A), 800Vdc (Ie=32A), 600Vdc (Ie=13, 32A), 500Vdc (Ie=32, 40A), 300Vdc (Ie=32, 40A).

R.A. Hill


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 05-03-19 181917/4a
Correction to General Modification



A P P R O V A L S ®

Certificate of Conformity

* Addendum *

Certificate No.: SAA-181917-EA

Date of Issue: 23 May 2019

Class Description: DC Isolator

Product Description: PV Switch-disconnector

General Modification:

Addition of breathing valve as per recommendation of CEC guideline Clause 7.9.5.

Additional Models	Description
SE042H	Similar to SE030E except for model number.

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 23-05-19 181917/5a
Model Description amended