



A P P R O V A L S ®

Certificate of Approval

Certificate No.: SAA-190427-EA

Certificate Holder: Citisolar QLD Pty Ltd As Trustee For
PGK Distributors Unit Trust t/as
PGK Distribution
8 Mohr Street
Tullamarine VIC 3043
Australia

Class Description: DC Isolator
Product Description: PV Switch-disconnector
Brand Name: PGK DISTRIBUTION
Model No.: SE030G
Markings: 1500Vdc (Ie=16A, 35A),
1200Vdc (Ie=32A, 50A)
1000Vdc (Ie=50A)
600Vdc/300Vdc (Ie=50A, 50A)
Uimp 8kV, Ithe Solar at 40°C: 50A,
Ithe Solar at 60°C: 50A
IP66NW, Ta:-40 to +85°C, DC-PV2

Standard: AS 60947.3:2018
AS/NZS IEC 60947.1:2015

Conditions: Nil

Approval Mark: RCM and SAA-190427-EA

Date First Registered: 19 February 2019
Date of Expiry: 19 February 2024

R.A. Hill


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 20-02-19 190427/1a
Correction to Markings



A P P R O V A L S ®

Certificate of Conformity

* Addendum *

Certificate No.: SAA-190427-EA

Date of Issue: 23 May 2019

Class Description: DC Isolator

Product Description: PV Switch-disconnector

General Modification:

Addition of breathing valve as per recommendation of CEC guideline Clause 7.9.5.

Additional Models	Description
SE030L	Similar to SE030G except without enclosure and suitable for panel mounting.
SE030K	Similar to SE030G except without enclosure and suitable for DIN rail and fixed mounting.

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 23-05-19 190427/2a
Model Description amended