

## Certificate of Suitability

Certificate No.: SAA192171

Certificate Holder: Citisolar QLD Pty Ltd As Trustee For

PGK Distributors Unit Trust t/as

PGK Distribution 8 Mohr Street

Tullamarine VIC 3043

Australia

Class Description: Non-Prescribed

Product Description: Weatherproof AC Switch-Disconnector (1-Pole)

Trade Name: PGK DISTRIBUTION

Model No.: SE070

Markings: 250Vac 50Hz 20A

Ith:63A AC-22A

IP66

Standard: AS 60947.3:2018

AS/NZS IEC 60947.1:2015

Conditions:

Nil

**Certification Mark:** 

RCM and SAA192171

**Date First Registered:** 

27 August 2019

Date of Expiry:

27 August 2024

For and on Behalf of

For and on Behalf of SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under Old Electrical Safety Act 2002 and Electrical Safety Regulations 2013 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 27-08-19 192171/1



APPROVALS®

## Certificate of Suitability

## \*Addendum\*

Certificate No.: SAA192171

Date of Issue: 27 August 2019

Class Description: Non-Prescribed
Product Description: Weatherproof AC Switch-Disconnector (1-Pole)

<b>Additional Models</b>	Trade Name	Rating	Description
SE071	PGK DISTRIBUTION	440Vac 50Hz 20A	3-Pole
SE072	PGK DISTRIBUTION	250Vac 50Hz 35A	1-Pole
SE073	PGK DISTRIBUTION	440Vac 50Hz 35A	3-Pole
SE074	PGK DISTRIBUTION	250Vac 50Hz 63A	1-Pole
SE075	PGK DISTRIBUTION	440Vac 50Hz 63A	3-Pole
SE076	PGK DISTRIBUTION	440Vac 50Hz 20A	2-Pole
SE078	PGK DISTRIBUTION	440Vac 50Hz 35A	2-Pole
SE080	PGK DISTRIBUTION	440Vac 50Hz 63A	2-Pole

f

For and on Behalf of SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013 certifies* in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate compiles with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au





Issued: 27-08-19 192171/2