

AC SERIES EV CHARGER

User installation manual



contents

SAFETY INFORMATION

Important safety instructions	PG 01
Cautions	PG 02
Notes	PG 02
Specification	PG 03
Power Comparison Table	PG 03
Features	PG 04

PREPARE FOR INSTALLATION

Minimum installation requirements	PG 05
Position	PG 06
Height	PG 06
Maximize Wi-Fi signal reception(for models with Wi-Fi function)	PG 06
Power supply	PG 07
Installation considerations	PG 08

IN THE BOX

In the box	PG 09

INSTALLATION INSTRUCTIONS

Step-by-step installation instructions (bottom entry wiring)	PG 10
Step-by-step installation instructions (top entry wiring) S	PG 12
tep-by-step installation instructions (rear entry wiring)	PG 14
Set the operating current	PG 16
Reinstall the sealing cover and turn on power	PG 16

contents

OPERATING STATUS

Power on checking	PG 17
Button	PG 17
LED lights instructions	PG 18
Buzzer prompt description	PG 22
Start to use? Download the APP here	PG 22

MAINTENANCE INSTRUCTIONS

Product overhaul	PG 23
Warranty description	PG 23
Safety notice	
Operation and maintenance risk notification	DC 24
User risk notification	PU 24
DLB Installation instructions	PG 24

DLB INSTALLATION INSTRUCTIONS

1 Phase Grid	PG 25
2 Phase Grid	PG 26
3 Phase Grid	PG 27
2 Live wire 1 earth wire power supply method	PG 28

safety instructions

IMPORTANT SAFETY INSTRUCTION

This document contains important instructions and warnings that must be followed when installing and maintaining the EV Charger.



WARNING

- 1 Read this entire mandatory document before installing or using the EV charger.
- 1 This device should be supervised when used around children.
- 1 The AC Series EV Charger must be grounded through a permanent wiring system or an equipment grounding conductor.
- 1 Do not install or use the EV Charger near flammable, explosive, harsh, or combustible materials, chemicals, or vapors.
- 1. Use the EV Charger only within the specified operating parameters.
- Never spray water or any other liquid directly at the wall mounted EV Charger. Never spray any liquid onto the charger handle or submerge the charger handle in liquid. Store the charger handle above the ground to prevent unnecessary exposure to contamination or moisture.
- 1 Stop using and do not use the EV Charger if it is defective, appears cracked, frayed, broken, or otherwise damaged, or fails to operate, or continue operation.
- Do not attempt to disassemble, repair, tamper with, or modify the EV Charger. The EV Charger is not user serviceable. Contact us for any repairs or modification.
- Transporting the EV Charger, handle with care. Do not subject it to strong force or impact or pull, twist, tangle, drag, or step on the EV Charger, to prevent damage to it or any components.
- 1 Do not touch the EV Charger's end terminals with sharp metallic objects, such as wire, tools, or needles.
- 1 Do not forcefully fold or apply pressure to any part of the EV Charger or damage it with sharp objects.

safety information

- Do not insert foreign objects into any part of the EV Charger.
- Use of the EV Charger may affect or impair the operation of any medical or implantable electronic devices, such as an implantable cardiac pacemaker or an implantable cardioverter defibrillator. Check with your electronic device manufacturer concerning the effects that charging may have on such electronic devices before using the EV Charger.

CAUTIONS

- Do not use private power generators as a power source for charging.
- Incorrect installation and testing of the EV Charger could potentially damage either the vehicle's Battery and/or the EV Charger itself. Any resulting damage is excluded from New Vehicle Limited Warranty and the EV Charger Limited Warranty.
- Do not operate the EV Charger in temperatures outside its operating range of -25°C to +55°C.
- 1 That adaptors or conversion adapters are not addowed to be used.
- 1 That cord extension sets are not allowed to be used.

NOTES

- Ensure that the EV Charger's charging cable is positioned so it will not bestepped on, driven over, tripped on, or subjected to damage or stress.
- Do not use cleaning solvents to clean any of the EV Charger's components. The outside of the EV Charger, the charging cable, and the connector end of the charging cable should be periodically wiped with a clean dry cloth to remove accumulation of dirt and dust.
- O Be careful not to damage the circuit board when removing the power entry knock-out.

safety information

SPECIFICATION

Description	Specification
Voltage and wiring	Single-phase or three-phase EV Charger:
	AC230V±10%;L1,N, PE Three-phase EV Charger:
	AC400V±10%;L1,L2,L3,N,PE
Current	6A/8A/10A/12A/16A/20A/25A/32A
Frequency	50/60HZ
Cable Length	5M/6M
EV charger dimensions	Height:380mm Width:169mm Depth:151/201mm
Gross Weight	7KG / 5KG
Operating temperature	-25°C~55°C
Enclosure rating	IP65 (Socket IP55)
Standby power	2W
Humidity	<95% No condensation
Altitude	≤2000M
Leakage Detection	TYPE A + DC6mA leakage sensor built-in

PRICE COMPARISON TABLE

	Voltage (V)	Current (A)	Power (W)
	230	6	1380
	230	8	1840
	230	10	2300
	230	12	2760
1-Phase EV Charger	230	16	3680
	230	20	4600
	230	25	5750
	230	32	7360
	230	6	4140
	230	8	5520
	230	10	6900
	230	12	8280
3-Phase EV Charger	230	16	11040
	230	20	13800
	230	25	17250
	230	32	22080

safety information

FEATURES

- O Built-in with over-voltage and under-voltage protection (U>264V or U<187V), over-current protection, over temperature protection, imperfect earth detection, CP abnormal signal protection and type A + DC 6mA for europe standard.
- O Operating temperature range: -25°C ~ +55°C
- O IP65 (Socket IP55) protecting rate, operating humidity range 0-95% for indoor and outdoor.
- O Includes temperature sensor build-in important areas for fire protection.
- O Includes leakage test function, ensuring leakage protection.
- The charger has a function of automatic reset after troubleshooting. That means the charger stop working when an anomaly is detected. The charger will periodically self-check whether the anomaly is eliminated. The charger will start to work automatically after ensuring the anomaly has been eliminated.
- O Easy cable storage.
- O The ramp-down stop current charging mode protects the EV batteries.
- The EV charger can be wall-mounted or pile mounted. There are three methods of wiring for the EV charger, bottom entry wiring, top entry wiring and rear entry wiring. You will need to install the wiring box to make top entry wiring.
- O RFID card or auto-start charging option.
- O Rated charging current can be set according to different home load conditions.
- With lightning protection ensure personal safety.



MINIMUM INSTALLATION REQUIREMENTS

Installation of the wall charger requires that you:

- O Calculate the existing electrical load to determine the maximum operating current.
- O Calculate the distance to ensure minimal voltage drop.
- Obtain any necessary permits from the local authority that has jurisdiction and confirm that the follow-up inspection has been scheduled by an electrician after the installation is complete.
- O Use only copper conductors.
- Use copper wire that meets the specifications of local wiring regulations. The selected cable must be capable of withstanding continuous oads of up to 40A at all times. The selected circuit protection device must incorporate an appropriate wall-mounted residual current device (RCD) and corresponding electrical load over current protection.

POSITION

- O Ensure that the parking position is within range of the charging cable.
- Ensure there is enough clearance for the charging cable to wrap around and the charging handle and can be comfortably positioned on the side of base.
- If installed in an enclosed garage, choose to install on the side of the EV charger slot.
 For outdoor installations, waterproof protection is recommended but not mandatory.
 Install in a well-ventilated space. Avoid installation in enclosed boxes or close to high power appliances.

HEIGHT

- O Maximum height (indoor and outdoor): 60 inches (1.5 m)
- O Recommended height: 47 in (~1.2 m)
- O Minimum outdoor height: 24 in (0.6 m)
- O Minimum interior height: 18 inches (0.45 m)

MAXIMIZE WI-FI SIGNAL RECEPTION (FOR MODELS WITH WI-FI FUNCTION)

- For achieving optimal functionality, the Wall Mounted Connector should be connected to the local Wi-Fi network. To maximize signal reception, avoid installing wall-mounted connectors against physical obstacles such asconcrete, masonry, metal poles, etc. that may prevent Wi-Fi signal reception.
- Note: If the mobile device can connect to local Wi-Fi in a specific location, the wall-mounted connector can also be connected.

POWER SUPPLY

• 230V single-phase power supply

- O For single-phase EV charger, a single-phase wire (L), Neutral and earth wire must be connected. The phase voltage between the Line and Neutral wires should be 230V.
- For 3-phase EV charger, connect the single phase wire (L1), the neutral wire and the earth wire do not connect the other phase wires (L2 or L3). The phase voltage between the line and neutral wires should be 230V.

400V three-phase power supply with neutral line

O If three phases are applied, all three phases (L1, L2 and L3) and the neutral line should be connected to each other and the voltage of each phase to the neutral line should be 230V.









- 🙏 Normally, the earth wire should be properly connected, otherwise the EV charger will not work.
- For situations where there is no earth connection, in order to enable the EV Charger to operate, it can be set via APP to turn off the earth detection and it will work, but it will reduce to the leakage protection safety level.
- 1 This AC Series AC EV charger must be grounded via a permanent electrical system or equipment grounding Conductor.
- A Before installing an AC EV charger, please confirm the type of grid connection available.
- 1. Note: Please consult your local electrician or refer to your local code in order to choose the proper wire for the AC EV charger current.

INSTALLATION CONSIDERATIONS

- Three methods are available to install the EV charger. The location of the conduit determines which installation method to follow. If the conduit runs along the floor or low on the wall, use the bottom entry configuration. If the conduit comes from inside the wall, use the rear entry configuration. If the available conduit comes from the ceiling, use the top entry installation.
- O Note: Throughout the manual, "conduit" is used as the standard term for the protective tubing that houses the service wiring. In regions where conduit is not used (Europe for example), a cable comprised of service wiring enclosed in a protective jacket may be substituted for conduit if allowed by local regulations.

Here are some additional guidelines

- O Conduit openings are sized for (32 mm) conduit.
- O Conduit needs to be metal and flame retardant.
- O Use an appropriate circuit breaker.
- O To keep the housing weatherproof, use cable glands.
- The EV charger doesn't come with the battery for safety shipping, we advise the users to buy the CR1220 battery or same size battery if the history record function is needed.
 Wi thout the battery, the function or the settings need to be reset after charger restart.

in the box



STEP-BY-STEP INSTALLATION INSTRUCTIONS (BOTTOM ENTRY WIRING)



Step 1

Position

The bottom of the (9) positioning plate is 1.2 m away (recommended), if the EV charger is installed close to the edge of the wall, the positioning plate should be more than 0.5 m away from the edge of the wall.

Drilling pilot holes

Drilling the holes according to the instruction on the Position template for different installation and wiring ways.



Step 2

Install the Mounting braket

Put the 8*40 Socket head screws' anchoring into the holes, and use the screw driver make the 6pcs 8*40 Socket head screws to fix the Mounting braket on the wall .

STEP-BY-STEP INSTALLATION INSTRUCTIONS (BOTTOM ENTRY WIRING)



Step 3

Install the EV Charger to the mounting plate

Align the side hole of EV charger to the panel's side holes.

Installation

Use the 4pcs M6*8 screws to fix the EV charger to the mounting plate as picture shows (Screws torque 1.5NM-2.0NM).



Step 4

Wiring

Note: Consult with your local electrician or refer to your local code for proper wire sizing appropriate for the currents in your EV Charger.

Note: It is the installer's responsibility to identify whether additional grounding is required to ensure that local regulations are met. Grounding must be installed at the power source and not at the cable entry to the EV Charger. As the picture at left shows, use the screwdriver loosing the screws on the EV charger cover. Wire the cable to the according terminal.

STEP-BY-STEP INSTALLATION INSTRUCTIONS (TOP ENTRY WIRING)



Step 1

Position

The bottom of the (9) positioning plate is 1.2 m away (recommended), if the EV charger is installed close to the edge of the wall, the positioning plate should be more than 0.5 m away from the edge of the wall.

Drilling pilot holes

Drilling the holes according to the instruction on the Position template for different installation and wiring ways.



Step 2

Fix the wire box

Put the 8*40 flat head screws' anchoring into the holes and use the screw driver make the 2pcs 8*40 flat head screws to fix the Wire box Mounting Template on the wall.the cable entry to the EV Charger.

As the picture at left shows, use the screwdriver loosing the screws on the EV charger cover. Wire the cable to the according terminal.

STEP-BY-STEP INSTALLATION INSTRUCTIONS (TOP ENTRY WIRING)



Step 3

Cut out on the back of the EV charger. Find the hole for cut out on the back of EV charger.

Use the 4pcs M6*8 screws to fix the EV charger to the mounting plate as picture shows (Screws torque 1.5NM-2.0NM).



Step 4

Wiring

Note: Consult with your local electrician or refer to your local code forproper wire sizing appropriate for the currents in your EV Charger.

Note: It is the installer's responsibility to identify whether additional grounding is required to ensure that local regulations are met.Grounding must be installed at the power source and not at the cable entry to the EV Charger. As the picture at left shows, use the screwdriver loosing the screws on the EV charger cover. Wire the cable to the according terminal.

STEP-BY-STEP INSTALLATION INSTRUCTIONS (REAR ENTRY WIRING)



Step 1

Position

The bottom of the (9) positioning plate is 1.2 m away (recommended), if the EV charger is installed close to the edge of the wall, the positioning plate should be more than 0.5 m away from the edge of the wall.

Drilling pilot holes

Drilling the holes according to the instruction on the Position template for different installation and wiring ways.



Step 2

Install the Mounting braket. Put the 8*40 socket head screws' anchoring into the holes, and use the screw driver make the 6pcs 8*40 Socket head screws to fix the mounting braket on the wall .

at the cable entry to the EV Charger. As the picture at left shows, use the screwdriver loosing the screws on the EV charger cover. Wire the cable to the according terminal.

STEP-BY-STEP INSTALLATION INSTRUCTIONS (REAR ENTRY WIRING)



Step 3

Install the EV Charger to the mounting plate.

Find the hole for cut out on the back of EV charger.

Use the 4pcs M6*8 screws to fix the EV charger to the mounting plate as picture shows (Screws torque 1.5NM-2.0NM).



Step 4

Wiring

Note: Consult with your local electrician or refer to your local code for proper wire sizing appropriate for the currents in your EV Charger.

Note: It is the installer's responsibility to identify whether additional grounding is required to ensure that local regulations are met. Grounding must be installed at the power sourceand not at the cable entry to the EV Charger.

As the picture at left shows, use the screwdriver loosing the screws on the EV charger cover. Wire the cable to the according terminal.



WARNING

- 1 Do not connect the power cord before reading and fully understanding all the concepts introduced in this section. If you are not sure whether the type of power supply on the repair panel is available, please consult an electrician for assistance.
- Be careful of electric shock! Before use, use a voltmeter to confirm that there is no voltage on the power supply line or terminal to ensure that the power has been cut off.

SET THE OPERATING CURRENT

- Do not connect the power cord before reading and fully understanding all the concepts introduced in this section. If you are not sure whether the type of power supply on the repair panel is available, please consult an electrician for assistance.
- Be careful of electric shock! Before use, use a voltmeter to confirm that there is no voltage on the power supply line or terminal to ensure that the power has been cut off.



REINSTALL THE SEALING COVER AND TURN ON POWER

Use a screwdriver to lightly secure the sealing cover by installing only the top screws at (1.5NM-2.0NM) torque.

After sealing cover fixing, put the facia on and fix it on the sealing cover.

If you need to open the front cover, change the internal settings, please use the (4) plastic lifter to unclench along the edge of the cover.

Recommend to install a circuit breaker 40A/2P 30MA.

POWER ON CHECKING

Ń	10.	Check Content
1.		Check and ensure the circuit breaker for the EV charger is reasonably selected
2		Confirm that there is no short circuit between the AC output L/N/PE of the charging
3		Confirm that the charging gun is not connected to the vehicle
4	ŀ.	Ensure the circuit breaker is closed
5).	The charger is powered on, and the power-on selfcheck is completed in about 10 seconds
6).	After the power-on self-check is completed, observe the status of the LED indicator Normal standby: Green breathing light ON. Equipment Failure: Yellow light on /Red light on (Please find below for reference)

BUTTON



 Emergency stop reset button: After press the button, yellow light is always on, EV Charger function is suspended. Rotate the button counterclockwise to recover from EV Charger faults.

Electric leakage test button: Press the button
 to test the electric leakage(if the red light is fllashing, the EV Charger detection function of electric leakage is normal), keep pressing the leakage test button for 10s, the EV Charger connection mode is initialized to Bluetooth mode. (smart types only)

POWER ON CHECKING

LED Behaviour	LED Status	Status Description	Potential Cause	Solution
0000	Lights OFF	No power supply	No power	Check the power source
	All lights on until blue lights breathe	Charger power ON self test		
	Blue lights turn into breathing and keep blinking	Standby		
	The blue lights on the right remain ON steadily	RFID initiated whilst on standby		

NORMAL STATUS

LED Behaviour	LED Status	Status Description	Potential Cause	Solution
	Blue light rotates back and forth	No RFID card swiping EV is not ready		
	The blue light starts from the middle & goes down from the left to right at the same time	After RFID swiping EV is not ready		
	The blue light starts from the middle & rotates clockwise	Charging		
	All blue lights are on	Charging finished		

NORMAL STATUS

LED Behaviour	LED Status	Status Description	Potential Cause	Solution
	All lights strobe (4 times per second)	Contactor	Contactor or tripping module	Check whether the vehicle charging is normal
	Yellow lights ON	Emergency stop protection	Emergency stop button is pressed	Rotate the emergency stop button Pop up reset
	Red lights ON	Grounding abnormality	The Ground wire is not wired or the neutral wire is reversed	Check whether the grid connection and charger wiring is correct
	Red Light once	Over Voltage	Power supply has short circuit or is unstable wire	1. Check power supply 2. Check the of power supply
	Red light twice	Under Voltage voltage is insufficient	Power Supply	1. Check the power supply 2. Check the wire of power supply
shina shina shina Shina Shina Shina Shina Shina Shina Shina Shina Shina Shina Shina Shina	Red light thrice	Leakage fault	Leakage occurs	1. Reset with emergency stop button 2. Check the charger connector or vehicle for leakage

NORMAL STATUS

LED Behaviour	LED Status	Status Description	Potential Cause	Solution
000	Red light flashes continuously (Once per second)	Over current	Short circuit may happen	Call for professional repair
000	Red light flashes (Quartic per second)	Over temperature alarm	High temperature	1. Wait for charger cooling 2. Ensure the wiring of charger terminal is not loosing
000	Alternating red and yellow continuously Red for 0.5 seconds	Abnormal CP signal	The connection between the charger and the vehicle is loose	1. Check if the connector is with water leakage 2. Ensure the connector is matched with EV
	Red and yellow lights flash once	Abnormal CC signal	The connection between the charger and the vehicle is loose	Check whether the charger connector is firmly inserted
	Yellow light ON triple	LED board is offline	LED board is faiult or loosing	Open the charger cover and check whether the light board cable is connected correctly and firmly
	Yellow light ON once, red light ON once	DLB is offline	The DLB connection is loose	Check the connection between DLB box & charger
	Yellow light ON	DLB abnormal	The connection	 1. 1. Check the CT of the DLB box is in the correct position 2. Check whether the DLB box CT is firmly clamped 3. Check if the phase sequence of the DLB box CT is correct 4. Check if the connection between the DLB box CT and the DLB box is firm

NORMAL STATUS

Buzzer	Status	Operating
Short buzzing one sound	Swipe to start	Start charging
Short buzzing two sounds	Swipe to quit	Stop charging
Long buzzing one sound	Swipe failue	NONE

START TO USE? DOWNLOAD THE APP



maintenance instructions

In order to ensure the normal service life of the charging pile and reduce the risk during use, it must be overhauled with in the specified time period; the overhaul of the equipment should be carried out by professionals, band qualified and safe overhaul tools should be used.

PRODUCT OVERHAUL

- O Regularly check whether the product is damaged.
- Ensure that the emergency stop, circuit breaker and other components of the product can be used under any circumstances, and conduct regular tests.
- If a ground fault occurs, first make sure that the grounding cable carries voltage, and then check that there is no high voltage in the system, and then repair the charger.

WARRANTY DESCRIPTION

- Free warranty is available for any damages or failures due to the chargers' quality problems 3 years from the date of factory production.
- Any damages caused by failure operatings, natural reasons, wrong install or use against with the instructions, is not covered by the warranty.
- Non-professionals are not allowed to repair the chargers. Any problems during installation or use, please contact the dealer first.

maintenance instructions

SAFETY NOTICE

Operation and maintence risk notificaton

- Do not disassemble or modify charging facilities and wiring without authorization, otherwise it may cause fire and electric shock accidents.
- In the event of a power failure or power failure, professional personnel or authorized operation and maintenance personnel must perform maintenance, otherwise there may be a risk of electric shock; charging equipment maintenance is not allowed when the power is not disconnected, and there is a risk of electric shock.
- The emergency stop switch should be inspected and maintained regularly to ensure that the emergency stop switch is effective.
- There should be no combustible and combustible materials around the charging equipment. If there is any, it should be cleaned up in time, othewise there is a risk of fire.

1-PHASE GRID

Normal DLB





2-PHASE GRID

Normal DLB





3-PHASE GRID

Normal DLB





2 LIVE WIRE 1 EARTH WIRE POWER SUPPLY METHOD

Normal DLB







VISIT WWW.SOLTARO.COM EMAIL INFO@SOLTARO.COM

OR CALL US ON

+61 1300 276 582 AUS +44 1909 807 577 EUR